



OFFICE OF PROCUREMENT SERVICES  
315 WEST MAIN STREET, SUITE 441  
PO BOX 7800  
TAVARES FL 32778-7800

PHONE: (352) 343-9839  
FAX: (352) 343-9473

[www.lakegovernment.com](http://www.lakegovernment.com)

#### **ADDENDUM NO. 4**

**Date: July 6, 2012**

**Invitation to Bid (ITB) No. 12-0224**

#### **NEW CONCESSION BUILDING FOR NORTH LAKE PARK**

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum with the initial bid or proposal response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid or proposal from being considered for award.

**This addendum \_\_\_ does X does not change the date for receipt of bids.**

The purpose of this addendum is to provide confirming information to all potential responding vendors in association with the cited Invitation to Bid. The information provided herein responds to additional inquiries from vendors. Questions 1 through 32 were addressed under addenda 2 and 3. It is the County's position that the matters addressed below can be resolved by full review and consideration of the bid documents and directions provided during the course of the mandatory pre-bid conference. Nevertheless, the questions and answers are being provided via addendum to ensure all bidders receive the same information at the same time.

**Question 33:** Addendum #3, Drawing Sheet E1.1 indicates a new 'Electric One Line Diagram'. This Drawing conflicts with the existing Power Panel Schedule on Drawing Sheet E4.1. Please provide a revised Power Panel Schedule to match the new E1.1 Drawing Sheet.

**Answer 33:** Refer to addendum no. 2 and 3

**Question 34:** The Site Lighting Scheduled on Drawing sheet C5.01 includes reference to Musco Lighting. This appears to conflict with the invitation to bid and the revised E1.1 Drawing which shows this lighting as future. Please confirm whether we are to include the Musco Lighting as part of the Contractor's Work.

**Answer 34:** Musco lighting not part of this bid

**Question 35:** The Site Lighting Scheduled on Drawing sheet C5.01 includes reference to street lighting but gives no direction on how this lighting is to be wired or where it is powered from. Please provide the location for the power supply and indicate how this street lighting is to be wired.

**Answer 35:** Street lighting not part of this bid

**Question 36:** Addendum #3, Drawing Sheet C5.02 includes details that refer to 'Building #4'. The Riser Diagram and gear on this Drawing do not match the current project. Please provide direction about how we are to apply the information detailed on Drawing Sheet C5.02.

**Answer 36:** Refer to addendum no. 2 and 3

**Question 37:** Please confirm whether the electrical work associated with the Scoreboards included on Drawing Sheet C6.04 is to be included as part of the Contractor's Work.

**Answer 37:** Scoreboard electrical work not part of this bid

**Question 38:** Please confirm whether all of the site lighting scheduled on Drawing Sheet C5.01 is to be included in the Contractor's Work. If not, please clarify which lighting is to be provided by others.

**Answer 38:** Only lighting mounted on building is part of this bid

**Question 39:** It appears that there are conflicts with the electrical design that will prevent our Electrical Contractors from accurately pricing the project. In light of these discrepancies, we request that the Owner extend the bid date and provide clarification toA the electrical design so that we may properly price this work.

**Answer 39:** As this addendum involves no change to any requirements of the ITB, no extension is required or granted.

**NOTE: Vendors are advised that the period for submission of inquiries is closed. The County may elect not to respond to further inquiries.**

Firm Name: \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_ Title: \_\_\_\_\_

Typed/Printed Name: \_\_\_\_\_